



**M. P. MADHYA KSHETRA VIDYUT VITARAN CO. LIMITED**

*(Wholly Owned Government of M. P. Undertaking)*

**Nishtha Parisar, Bijalee Nagar, Govindpura, Bhopal - 462 023**

☎ 0755-2602033-34 & 35; Fax: 2589821; Website: [www: madhyavitaran.nic.in](http://www.madhyavitaran.nic.in)

[www : rapdrp.bhopal@gmail.com](mailto:www:rapdrp.bhopal@gmail.com)

No. CMD/MK/RAPDRP-A/SIA/ C-51/ 338

Bhopal, dated- 30.06.2011

**Addendum -6**

In continuation to the clarifications released against RFP no. No. CMD/MK/RAPDRP-A/SIA/ 214 dated 05.05.2011 as Addendum-4 vide letter no. CMD/MK/RAPDRP-A/SIA/C-51/302 dated 13.06.2011, the following points are further clarified:

1. Reference section-2, chapter-5, para-5.2.1 server: The following servers shall be supplied with 8 GB RAM as minimum.
  - a) Application Servers
    - SCADA/DMS Server
    - ISR
    - NMS
    - Web server
    - DR Server
  - b) The following servers shall be supplied with 4 GB RAM as minimum.
    - ICCP/Inter Control Center Communication Server
    - Front –End server (Communication Front End) FEP (CFE)
    - DMZ
    - Training & Development Server
2. Reference section -2 chapter-5 para- 5.2.4 WAN Router: Routers shall have capabilities and shall support mentioned interfaces and quantity of ports with scalability as required in the MTS. Total no of ports shall be determined by the connectivity requirement.
3. The prices shown in Price proposal Appendix C-3 against mandatory spares should be supported by an Annexure indicating their unit prices and quantity.

4. The Price shown against FRTU and RTU in Price proposal Appendix C-3 should be supported by an Annexure, indicating substation/location wise, and Town wise prices, with their totals & subtotals.
5. The SIA shall deliver quality workmanship with good ergonomics and aesthetics, especially in case of retrofitting. The wiring should be neatly dressed with proper ferruling and termination.
6. The due date for submission of bid is extended as under:

Due Date for submission of Response.	12th July 2011 before 15:00 Hrs
Date and time of opening of the Bids	12th July 2011 at 15:30 Hrs Conference Room, MPMKVVCL, Nishtha Parisar, Govindpura, Bhopal.

7. All other terms and conditions of the RFP including the addendums remain unchanged.

It is requested to forward names of the representatives to enable this office to arrange the passes.



**Project Director (RAPDRP Part-A)  
MPMKVVCL, Bhopal**