



**OFFICE OF THE CHAIRMAN & MANAGING DIRECTOR
M.P.MADHYA KSHETRA VIDYUT VITARAN CO. LTD.**

(A Wholly Owned Govt. of M.P.Undertaking)

NISHTHA PARISAR, BIJLINAGAR, GOVINDPURA, BHOPAL-462023

Phone: 2602033-36, 2678325, 2678280, Fax No.2589821 E.mail ce_purchase@mpmkvvc.com

Ref. No.CMD/MK/04/ P-I/ 304

Bhopal, dated 27.04.11

CORRIGENDUM

Sub. :Tender Specification No. CMD/MK/04/210 for procurement of Push Fit Type Tamper Proof Meter Box for Single Phase and Three Phase Energy Meter.

The following amendments may please be noted before submission of the tender :

Sr. No.	Reference	Written as	Amended/ Clarified as
1	Clause No. 1(iv), Annexure-III Important Instructions to Bidders (Page-6)	Such type test certificates should not be older than two years as on the date of opening of tender.	Such type test certificates should not be older than five years as on the date of opening of tender.
2	Clause No. 3.3, Schedule II (A) Technical Specifications (Page-10)	The minimum inside dimensions of the meter box shall be suitable for installation of all types of meters purchased from various meter manufacturers	Stands Deleted
3	Clause No. 3.4, Schedule II (A) Technical Specifications (Page-10)	The single phase and three phase meter box shall be such that there should be minimum 60 mm clearance at the bottom, 40 mm clearance on all three sides, 25 mm clearance at the front and 10 mm clearance at the back between meter and meter box inner wall	Stands Deleted. Except 10 mm clearance at the back between meter and meter box inner wall
4	Clause No. 3.18, Schedule II (A) Technical Specifications (Page-11)	4 nos. of keyholes of diameter 6 mm shall be provided at the backside of the meter box to facilitate mounting of the meter box on the wall or pole.	2 nos. of keyholes + 2 nos. of round holes of diameter 6 mm shall be provided at the backside of the meter box to facilitate mounting of the meter box on the wall or pole.
5.	Clause No. 3.23, Schedule	The box shall have the same serial no etched / printed in	The same serial no. shall be etched / printed, on the base,

Sr. No.	Reference	Written as	Amended/ Clarified as
	II (A) Technical Specifications (Page-12)	six locations in the box, 1 each on the 2 Nos. seals, 1 on the base and 1 on the cover and 2 on the polycarbonate seals provided in the box	cover and all seals provided in the box
6.	Clause No. 4 II (16), Schedule II (A) Technical Specifications (Page-13)	“Boiling water test”.	Stands Deleted.
7.	Clause No. 4 II (15), Schedule II (A) Technical Specifications (Page-13)	“Voltage Withstand Test 5 KV”	It is clarified that Voltage Withstand Test 5 KV has to be applied between 2 points on the meter box base for one minute and there shall be no flash over.
8.	Sl. No. 5, Schedule – II (B) GTP, (Page 15)	“Dimensions of Meter Box” (a) Height 260 mm $\pm 5\%$ (b) Width 190 mm $\pm 5\%$ (c) Depth 120 mm $\pm 5\%$	“Dimensions of Meter Box” may be read as (a) Height 260 mm (b) Width 190 mm (c) Depth 120 mm With tolerance of +10%-5%.
	Sl. No. 5, Schedule – II (C) GTP, (Page 11)	“Dimensions of Meter Box” (a) Height 400 mm +5% (b) Width 250 mm +5% (c) Depth 135 mm +5%	“Dimensions of Meter Box” may be read as (a) Height 400 mm (b) Width 250 mm (c) Depth 135 mm With tolerance of +10%-5%.
9.	Sl. No. 17, Schedule – II (B) GTP, (Page 16)	Weight of Meter Box-750 gms. approx.	Minimum Weight of Meter Box-600 gms.
10.	Sl. No. 18, Schedule – II (C) GTP, (Page 18)	Weight of Meter Box-1400 gms. approx.	Minimum Weight of Meter Box-1200 gms.
11.		Tolerances and dimensions mentioned in the drawing Schedule II (D) & II (E)	It is clarified that the all the dimensions and tolerances given in GTP & technical specifications shall hold good for supply of meters.

The other details, terms & conditions of the original tender will remain the same.

(Sanjeev. P. Puranik)
CHIEF GENERAL MANAGER (PUR)
O/o CMD, MPMKVV CO. LTD. BHOPAL



**OFFICE OF THE CHAIRMAN & MANAGING DIRECTOR
M.P.MADHYA KSHETRA VIDYUT VITARAN CO. LTD.
(A Wholly Owned Govt. of M.P.Undertaking)**

NISHTHA PARISAR, BIJLINAGAR, GOVINDPURA, BHOPAL-462023
Phone: 2602033-36, 2678325, 2678280, Fax No.2589821 E.mail ce_purchase@mpmkvvc.com

Ref. No.CMD/MK/04/ P-I/303

Bhopal, dated 27.04.11

CORRIGENDUM

The due date of opening of Tender Specification No. CMD/MK/04/210 for procurement of Push Fit Type Tamper Proof Meter Box for Single Phase and Three Phase Energy Meter is hereby extended. The revised date of opening of the tender shall be now **13.05.11** instead of **28.04.11**. The EMD of Rs. 50,000/- in favour of Sr. A.O (HOAU), MPMKVV Co. Ltd. payable at Bhopal along with hard copy of tender & supporting documents duly filled up excluding Schedule I (Price & Quantity) shall be dropped in the tender box of Purchase Section, O/o CMD, Bhopal on date 12.05.2011 at 03:30 PM. The revised key dates shall be as under :

Seq No	MPMKVVC Stage	Contractor Stage	Start Date & Time	Expiry Date & Time
1	Tender Preparation And Release of NIT	-	03-04-2011 10:30	07-04-2011 17:30
2	-	Tender Purchase - Online	07-04-2011 17:31	10-05-2011 12:30
3	-	Tender Download	07-04-2011 17:31	11-05-2011 12:30
4	-	Submit Bid - Hash Online	07-04-2011 17:31	11-05-2011 15:30
5	Close for Bidding - Generation of Super Hash	-	11-05-2011 15:31	11-05-2011 17:30
6	-	Submit Bids Online - Re-encryption	11-05-2011 17:31	13-05-2011 14:30
7	Open EMD & Technical / PQ bid	-	13-05-2011 15:30	13-05-2011 17:00
8	Open Financial / Price-Bid	-	15-06-2011 15:30	15-06-2011 17:30

The other details, terms & conditions of the original tender will remain the same.

(Sanjeev. P. Puranik)
CHIEF GENERAL MANAGER (PUR)
O/o CMD, MPMKVV CO. LTD. BHOPAL