



**OFFICE OF THE CHAIRMAN & MANAGING DIRECTOR  
M.P.MADHYA KSHETRA VIDYUT VITARAN CO. LTD.  
(A Wholly Owned Govt. of M.P.Undertaking)**

**NISHTHA PARISAR, BIJLINAGAR, GOVINDPURA, BHOPAL-462023**

Phone: 2602033-36, 2678325, 2678280, Fax No.2589821 E.mail ce\_purchase@mpmkvvc.com

**Ref. No.CMD/MK/04/ P-I/2306**

**Bhopal, dated 07.10.11**

**CORRIGENDUM**

The due date of opening of Tender Specification No. CMD/MK/04/220 for supply of 33 KV & 11 KV Porcelain Clad Vacuum Circuit Breakers and Control & Relay Panel is hereby extended. The revised date of opening of the tender shall be now **19.10.11** instead of **12.10.11**. The EMD of Rs. 50,000/- in favour of Sr. A.O (HOAU), MPMKVV Co. Ltd. payable at Bhopal along with hard copy of tender & supporting documents duly filled up excluding Schedule I shall be dropped in the tender box of Purchase Section, O/o CMD, Bhopal on date **18.10.11** till 3.00 p.m. The revised key dates shall be as under:

**Key Dates : Single Submission MultiOpening With Prequal**

Seq No	MPMKVVC Stage	Contractor Stage	Start Date & Time	Expiry Date & Time
1	Tender Preparation And Release of NIT	-	17-08-2011 10:30	09-09-2011 17:00
2	-	Tender Purchase - Online	09-09-2011 17:31	15-10-2011 10:30
3	-	Tender Download	09-09-2011 17:31	15-10-2011 12:30
4	-	Submit Bid - Hash Online	09-09-2011 17:31	15-10-2011 13:30
5	Close for Bidding - Generation of Super Hash	-	15-10-2011 13:31	15-10-2011 17:30
6	-	Submit Bids Online - Re-encryption	15-10-2011 17:31	19-10-2011 12:30
7	Open EMD & Technical / PQ bid	-	19-10-2011 15:30	19-10-2011 17:30
8	Open Financial / Price-Bid	-	14-11-2011 15:30	14-11-2011 17:30

Further, following amendments may please be noted before submission of the Tender:

Sr. No.	Reference	Written as	Amended/ Clarified as
1.	Clause No. 15.1(x), Schedule II (B) Technical Specifications (Page-55)	Master trip relay 30 V DC with hand reset and flag type having minimum 5 No. + 1 NC contacts for transformer panel. <b>11KV</b> <b>33KV</b> <b>Xmer Feeder</b> <b>Xmer Feeder</b> 1 No. Nil            1 No. Nil	Master trip relay 30 V DC with hand reset and flag type having minimum 5 No. + 1 NC contacts for transformer and feeder panel both. <b>11KV</b> <b>33KV</b> <b>Xmer Feeder</b> <b>Xmer Feeder</b> 1 No. 1 No.        1 No. 1 No.  <b>It is clarified that 1 No. master trip relay is to be provided for feeder panel also.</b>

The other details, terms & conditions of the original tender will remain the same.

(Sanjeev P. Puranik)  
**CHIEF GENERAL MANAGER (PUR)**  
**O/o CMD, MPMKVV CO. LTD. BHOPAL**